

LIA Laboratory Limited



Certificate of Product Certification

Certificate Number: 001-0001

***This is to certify that 'E27 Porcelain Batten Type Lampholder'
Model Ref: 5022***

Placed on the market by:

S Lilley & Son Ltd

80 Alcester Street
Birmingham
West Midlands
B12 0QE
United Kingdom

meet the requirements of the LIA Laboratory Product Conformity Scheme 'TSD-001'.

26 November 2019

Date of Initial Registration

20 February 2023

Date of Last Issue

25 November 2025

Date of Expiry

The validity of this certificate is subject to continuing conformity with The LIA Laboratory Ltd.'s TSD-001 scheme requirements. The absence of any products listed on certificate but not on the LIA Laboratory certification website indicates that certification of that product is no longer valid.



theLIA
Laboratory



5449

A handwritten signature in black ink, appearing to read 'Anton Borovy'.

Anton Borovy
Certification Business & Accreditation
Manager

**Signed on behalf of LIA Laboratory
Ltd**

Issued by: LIA Laboratory Ltd, Stafford Park 7,
Telford, Shropshire, TF3 3BQ

For verification of this certificate please visit
www.lialabcert.org.uk/certificates-search

Manufacturer:

S Lilley & Son Ltd
80 Alcester Street
Birmingham
West Midlands
B12 0QE
United Kingdom

Standard(s)

BS EN 60238:2018 + Amd1:2018

National differences

UK, AU, NZ

Test report(s)

LH1013A Amd 1

Technical characteristics

Type of lampholder.....:	E27
Rated voltage.....:	250V
Rated current.....:	4A
Degree of protection against electric shock...:	IP20
Temperature marking of lampholder.....:	T270