

# LIA Laboratory Limited



## Certificate of Product Certification

Certificate Number: 001-0001/A1

*This is to certify that 'E27 Porcelain Batten Type Lampholder'*

*Model Ref: 5022*

Placed on the market by:



S Lilley & Son Ltd  
80 Alcester Street  
Birmingham  
West Midlands  
B12 0QE  
United Kingdom

**meet the requirements of the LIA Laboratory Product Conformity Scheme 'TSD-001'.**

26 November 2019

Date of Initial Registration

06 February 2024

Date of Last Issue

25 November 2027

Date of Expiry

The validity of this certificate is subject to continuing conformity with The LIA Laboratory Ltd.'s TSD-001 scheme requirements. The absence of any products listed on certificate but not on the LIA Laboratory certification website indicates that certification of that product is no longer valid.



theLIA  
Laboratory



5449

A handwritten signature in black ink.

Anton Borovy  
Certification Business & Accreditation  
Manager

**Signed on behalf of LIA Laboratory  
Ltd**

Issued by: LIA Laboratory Ltd, Stafford Park 7,  
Telford, Shropshire, TF3 3BQ

For verification of this certificate please visit  
[www.lialabcert.org.uk/certificates-search](http://www.lialabcert.org.uk/certificates-search)

**Manufacturer:**

S Lilley & Son Ltd  
80 Alcester Street  
Birmingham  
West Midlands  
B12 0QE  
United Kingdom

**Standard(s)**

BS EN IEC 60238:2018+A1+A2:2021;  
AS/NZS 60238:2015+A1

**National differences**

UK, AU, NZ

**Test report(s)**

LH1025

**Technical characteristics**

Type of lampholder.....:	E27
Rated voltage.....:	250V
Rated current.....:	4A
Degree of protection against electric shock...:	IP20
Temperature marking of lampholder.....:	T270